

Jon Niermann, *Chairman*  
Emily Lindley, *Commissioner*  
Bobby Janecka, *Commissioner*  
Toby Baker, *Executive Director*



PWS\_2270014\_CO\_20190920\_Plan Ltr

## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

*Protecting Texas by Reducing and Preventing Pollution*

September 20, 2019

Mr. Jason G. Saylor, P.E.  
Utility Services Company, Inc.  
1230 Peachtree Street Northeast  
Atlanta, Georgia 30309

Re: City of Pflugerville - Public Water System ID No. 2270014  
Proposed 1,500,000 gallon South Standpipe Renovation  
Engineer Contact Telephone: (678) 705-0884  
Plan Review Log No. P-07232019-143  
Travis County, Texas

CN: 600412985; RN: 101430064

Dear Mr. Saylor:

On July 23, 2019, the Texas Commission on Environmental Quality (TCEQ) received planning material with your letter dated July 17, 2019 for the proposed 1,500,000 gallon South Standpipe Renovation. Based on our review of the information submitted, the project generally meets the minimum requirements of Title 30 Texas Administrative Code (TAC) Chapter 290 - Rules and Regulations for Public Water Systems and is **conditionally approved for construction** if the project plans and specifications meet the following requirement(s):

**§290.43(c)(3)** Overflows shall be designed in strict accordance with current AWWA standards. The discharge opening shall be covered with a gravity-hinged and weighted cover, an elastomeric duckbill valve, or other approved device to prevent the entrance of insects and other nuisances. When the tank is not overflowing, the cover shall close automatically and fit tightly with no gap over 1/16 inch. **Please insure the cover closes with a gap less than 1/16<sup>th</sup> inch.**

The submittal consisted of 1 sheet of engineering drawings and technical specifications. The approved project consists of:

- Interior and Exterior Coating of existing 1,500,000 gallon Standpipe;
- Installation of gravity-hinged overflow cover; and,
- Various fittings and related appurtenances.

This approval is for the construction of the above listed items only. Any wastewater components contained in this design were not considered.

The City of Pflugerville public water supply system provides water treatment.

The project is located at the corner of Club Chase Drive and Cherokee Run, Pflugerville, in Travis County, Texas.

Mr. Jason G. Saylor, P.E.  
Page 2  
September 20, 2019

An appointed engineer must notify the TCEQ's Region 11 Office in Austin at (512) 339-2929 when construction will start. Please keep in mind that upon completion of the water works project, the engineer or owner will notify the commission's Water Supply Division, in writing, as to its completion and attest to the fact that the completed work is substantially in accordance with the plans and change orders on file with the commission as required in 30 TAC §290.39(h)(3).

Please refer to the Plan Review Team's Log No. P-07232019-143 in all correspondence for this project.

Please complete a copy of the most current Public Water System Plan Review Submittal form for any future submittals to TCEQ. Every blank on the form must be completed to minimize any delays in the review of your project. The document is available on TCEQ's website at the address shown below. You can also download the most current plan submittal checklists and forms from the same address.

<https://www.tceq.texas.gov/drinkingwater/udpubs.html>

For future reference, you can review part of the Plan Review Team's database to see if we have received your project. This is available on TCEQ's website at the following address:


<https://www.tceq.texas.gov/drinkingwater/planrev.html/#status>

You can download the latest revision of 30 TAC Chapter 290 - Rules and Regulations for Public Water Systems from this site.

If you have any questions concerning this letter or need further assistance, please contact David Yager at 512-239-0605 or by email at David.Yager@Tceq.Texas.Gov or by correspondence at the following address:

Plan Review Team, MC-159  
Texas Commission on Environmental Quality  
P.O. Box 13087  
Austin, Texas 78711-3087

Sincerely,



David H. Yager, P.E.  
Plan Review Team  
Plan and Technical Review Section  
Water Supply Division  
Texas Commission on Environmental Quality



Vera Poe, P.E., Team Leader  
Plan Review Team  
Plan and Technical Review Section  
Water Supply Division  
Texas Commission on Environmental Quality

VP/DY/

cc: City of Pflugerville, Attn: Victor Gonzales, PO Box 589, Pflugerville, Texas 78691-0589