



DCS Engineering, LLC
1101 S. Capital of Texas Highway
Building G-100
Austin, Texas 78746

Tel: (512) 614-6171
Fax: (512) 284-8021
T.B.P.E. Firm No F- 13162
www.DCS-Engineering.com

June 14, 2019

Ms. Patricia Davis, P.E.
City of Pflugerville
City Engineer
15500 Sun Light Near Way #B
P.O. Box 589
Pflugerville, Texas 78660-0589

Re: City of Pflugerville – Weiss Lane Lift Station Rehabilitation
Recommendation to Award Contract

Dear Ms. Davis:

On June 13, 2019, DCS Engineering (DCS) assisted City of Pflugerville in opening bids for the above referenced project. Four (4) bid proposals were received with total base bid prices ranging from \$179,427.00 to \$249,820.00. A tabulation of the bids received is attached. The apparent low bidder for the total base bid is Protas Construction Inc and Protas Inc, a Joint Venture from Austin, Texas.

DCS has reviewed the bid proposal submitted by Protas Construction Inc and Protas Inc, Joint Venture and found it to be accurate and complete. DCS also obtained a Dun and Bradstreet Business Information Report for the company. The report stated that the company has a “low-mod” credit risk and shows the majority of payments to suppliers are within terms.

Based on the information presented, we recommend that the City accept the base bid of Protas Construction Inc and Protas Inc, JV (a Joint Venture) for the Total Base Bid amount of \$179,427.00 for furnishing all labor; material, tools and equipment and performing all work required for by-pass pumping, removal and replacement of Pump # 3 discharge elbow, removal and replacement of Pump #2 guiderail system, removal and replacement of one section of 12-inch riser pipe for pump #1, and installation of automatic air/vacuum release valves on all three existing pump discharges within the valve vault. We have prepared the attached NOTICE OF INTENT TO AWARD letter for your review. If the City is agreeable, DCS will mail the attached form on behalf of the City to Protas Construction Inc and Protas Inc, Joint Venture to initiate the preparation of the agreement documentation.

If you have any questions, please call me at (512) 614-6171.

Sincerely,

DCS Engineering, LLC

Darren C Strozewski, P.E.
Project Manager



6/14/19

Enclosures