



CITY OF PFLUGERVILLE SURFACE WTP STANDBY GENERATOR PRE-SELECTION

ADDENDUM #1

- I. Front End Documents
 - A. Delete the Table of Contents in its entirety and replace it with the new Table of Contents (**see attached**).
 - B. Delete the Certificate of Insurance document in its entirety.
 - C. Delete the Bid Bond document in its entirety.
 - D. Delete the Notice of Award document in its entirety.
 - E. Delete the Notice to Proceed document in its entirety.
 - F. Delete the Performance Bond document in its entirety.
 - G. Delete the Payment Bond document in its entirety.
 - H. Add the Purchasing Rider Form (**see attached**) to the front end documents following the Conflict of Interest Questionnaire.

- II. Specifications
 - A. Specification 26 32 13 – Tier IV Generator System
 - 1. Delete Paragraph 1.01.D.

- III. Questions from Prospective Bidders
 - A. Is vendor responsible for providing bonds for this purchase? Typically provided by General Contractor.
Answer: Bid Bond, Performance Bonds, and Payment Bonds will not be required.
 - B. Confirmation that 2,250KW is Prime Rated. *Answer: Per bid documents, the generator will be 2,250KW, Tier 4 Final, Prime rated.*

- C. What is the future site plan and is there already a generator at the location? *Answer: No generator is onsite. Refer to Pre-selection drawings for the future generator location.*
- D. Has a determination been made about the Volvo genset that has been asked on Civcast? *Answer: Volvo Penta Tier 4 Final Engine will not be accepted for this project.*
- E. Are bids to be hand-delivered? *Answer: Bids can be mailed or hand-delivered to the city of Pflugerville City Hall, but must be delivered before the bid due date. Electronic bids are not accepted.*
- F. Can you confirm the number of hours the generators are anticipated to run? *Answer: Generator set shall be capable of operating an unlimited number of hours with maximum load of 2250kW with 70% average load factor.*

END OF ADDENDUM #1



22 September 2021
Gupta & Associates, Inc.
TBPELS Firm Registration #F-2593