

2020-8705

Discuss and consider action to authorize the City Manager to approve the procurement of a replacement gearbox for Aerator # 2 for the Central Wastewater Treatment Plant in the amount of \$116,200 to Ovivo USA LLC.



Aerator Replacement

- Aerator 2 was found with a gearbox bearing failure.
- If aerator gearbox isn't replaced, the WWTP risks having increased ammonia levels which could result in effluent excursions and potential fines from TCEQ if not corrected.
- Best value to City was to replace gearbox instead of repair.



City staff recommends approval of the procurement of a replacement gearbox for Aerator # 2 for the Central Wastewater Treatment Plant in the amount of \$116,200 to Ovivo USA LLC.

