



City of Pflugerville

Legislation Details (With Text)

File #: 2021-1000 **Version:** 1 **Name:**

Type: Agenda Item **Status:** Approved

File created: 9/16/2021 **In control:** Public Works

On agenda: 9/28/2021 **Final action:** 9/28/2021

Title: Authorizing the City Manager to award a construction contract for the Colorado River Raw Water Intake Screens to Underwater Construction Corporation in the amount of \$254,756.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 20210917 City of Pflugerville Colorado River Screen Replacement LOR, 2. Addendum No. 1_Co. Raw Water Intake Screen Replacements, 3. Notice to Bidders for Newspaper_Pf RW Intake Screen Replacements, 4. Addendum No. 2_Co. Raw Water Intake Screen Replacement, 5. River Intake Screens - 2021-1000

Date	Ver.	Action By	Action	Result
9/28/2021	1	City Council	Approved	Pass

Authorizing the City Manager to award a construction contract for the Colorado River Raw Water Intake Screens to Underwater Construction Corporation in the amount of \$254,756.

The City’s Colorado River Intake currently diverts all of the raw water from the Colorado River to fill Lake Pflugerville. This intake system is the primary source of the City’s drinking water and will be absolutely critical to effectively maintain for years to come. The Colorado River Basin, along with many other water bodies around the Central Texas region, currently has zebra mussels that have found their way into and around our Colorado River Intake. This invasive species will attach to any infrastructure that it can and thrive for years if left alone. Staff have found evidence that the invasive species will attach to the intake screens over time and will have to be manually scraped off as the air burst system does not effectively remove them from the screens. Without this intervention, the screens would have a diminished flow throughput which could create significant problems during peak summer demands.

On November 24, 2020, City Council approved the treatment system that is currently in place that protects the suction and discharge pipelines from the mussels from attaching and being transported alive into Lake Pflugerville. This treatment system does not protect the suction screens where the water is currently being pulled through as we were limited to the location of the injection of the treatment chemical. This contract will replace the current stainless steel screens with a copper-nickel screen that has proven in various water utilities to prevent the accumulation of zebra mussels on the screens. These types of screens have been installed or are being installed in surrounding cities where their source water is considered “infested” with zebra mussels. The City has had successful projects with Underwater Construction Corporation in the past at the Colorado River Intake and they have always completed the work on-time and the work has been satisfactory.

The funding for this project is included in the FY2021 budget under the Colorado River Intake Screen Sourcing System as part of the Water Capital Improvement Program.

Prior City Council Action

NA

Deadline for City Council Action

September 28, 2021

Funding Expected: Revenue ___ Expenditure N/A ___

Budgeted Item: Yes No ___ N/A ___

*Project will be funded by CO Bond Funds.

Amount: \$254,756

1295 Form Required? Yes No ___

Legal Review Required: N/A ___ Required Date Completed: _____

Supporting documents attached:

Invitation for Bids, Addendum 1, Addendum 2, Recommendation Letter

Recommended Action

Staff recommends authorizing the City Manager to award a construction contract for the Colorado River Raw Water Intake Screens to Underwater Construction Corporation in the amount of \$254,756.