



# City of Pflugerville

## Legislation Text

---

**File #:** 2023-0410, **Version:** 1

---

Discuss and consider action regarding an application for a waiver to increase driveway widths greater than 20% of the maximum allowed under Table 10.2.1C Type II Driveway Criteria, associated with a site development plan application generally located along the SH-130 frontage road, north of E Pflugerville Parkway, at 2113 Elan Street, Pflugerville, Texas, to be known as Hayden Grove of Pflugerville (2023-2-VAR).

The request under consideration is to grant a waiver to site development regulations in excess of 20% of the requirement. The applicant is requesting the waiver to allow for two driveways to be extended to a width of 32.1-feet and 54.2-feet.

The proposed site plan and driveway widths have been reviewed by city staff, including engineering staff. The proposed driveway widths do not constitute a design concern and would be able to accommodate fire and emergency vehicle turning movements.

For these reasons, staff recommends approval of the proposed waiver as indicated in the Driveway Concept Plan attachment.

Nathan Jones, Planning Manager

Staff Report  
Location Map  
Driveway Concept Plan  
Applicant Letter of Intent